

EU-Type Examination Certificate
in accordance with Module B (Production Type) of Annex III of Pressure Equipment Directive 2014/68/EU

Certificate No: HSB IE 20-12-005 Rev.1

HSB IE Registration No: KR.DK.1069.00-B

Manufacturer	DK-Lok Corporation	
	7, Goldenroot-ro,129beon-gil, Juchon-myeon,Gimhae-si Gyeongsangnam-do, 50969 Republic of Korea	

Pressure Equipment:	Single Pressure Vessel (Pressure / Safety Accessorie)				
	Type/Scope:	Safety Relief Valves V63, V64 and V66			
	Standard Applied:	ASME B16.34, 2017 Edition ASME B31.3, 2018 Edition			
	Drawing No:	V63 & V66-MD-XX, Rev.:2 V64-F-8N16N, Rev.:0			
	Technical File:	Rev.:			
	Particular Material Appraisal(s):	DK-CEPMA-001, Rev. 0 / A182 F316 / L DK-CEPMA-002, Rev. 0 / A479 Type 316 / L DK-CEPMA-003, Rev. 0 / A351 CF3M / CF8M DK-CEPMA-004, Rev. 0 / A216 Gr. WCB			
	Other documents:				

Chamber:	V63	V64	V66
Maximum Allowable Pressure PS (bar):	20,6	414	414
Max./Min. Allowable Temperature TS (°C):	204°C / -28°C	204°C / -28°C	204°C / -28°C
Volume V (Liter)/Nominal Size DN (mm):	DN 4,8 mm (orifice)	DN 10,26 mm (orifice)	DN 3,4 mm (orifice)
Contents (Fluid Group):		2	
Calculated Test Pressure (barg):	31	621	621
Pressure Test Date:		22.October.2020	

Hartford Steam Boiler Ireland Limited



Certificate No.: HSB IE 20-12-005

HSB IE-Registration No.: KR.DK.1069.00-B

Restrictions:

The undersigned Notified Body certifies that the construction, fabrication and testing of the described pressure equipment meets the requirements of the Pressure Equipment Directive 2014/68/EU.

This Certificate is based on the representative example of pressure equipment and the relative data presented to the Notified Body.

Identification Number of the Notified Body: 2833

Certification Date: 04. December . 2020 **Expiry Date:** 03. December . 2030

This Certificate can be renewed upon request

C O'Donnell		16. Nov 2022
Name	Signature	Date

Hartford Steam Boiler Ireland Limited